

## ac units at gateway

8/22/2012 1:15:00 PM

Hall way unit 400 does not work  
600 wing hall way unit does not work  
south library hall unit does not work  
500 hole in suction line was braised and recharged  
703 new indoor blower motor installed  
502 two new compressors installed new header installed 2 new reversing valves installed  
601 new compressor installed  
welcome center new reversing valve installed  
806 new outdoor fan motor and cap installed  
853 new compressor installed  
852 teachers lounge new outdoor fan motor and cap installed  
center east unit on cafeteria mpr one of two compressors installed  
front office hall unit has been replaced  
404 unit has been replace  
maintenance shop unit has been replace with older unit from papago

## ac units at gateway

8/22/2012 1:15:00 PM

Hall way unit 400 does not work

600 wing hall way unit does not work

south library hall unit does not work

500 hole in suction line was braised and recharged

703 new indoor blower motor installed

502 two new compressors installed new header installed 2 new reversing valves installed

601 new compressor installed

welcome center new reversing valve installed

806 new outdoor fan motor and cap installed

853 new compressor installed

852 teachers lounge new outdoor fan motor and cap installed

center east unit on cafeteria mpr one of two compressors installed

front office hall unit has been replaced

404 unit has been replace

maintenance shop unit has been replace with older unit from papago

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
3043	HVAC 816 cycling on and off every 5 minutes Closed Work Orders	5/4/2007 5/15/2007	Rob Bauer	Held, David	Gateway Elementary School Hallway/Corridor
3331	HVAC 509 is blowing hot air and wont cool room, reset unit with negative results Closed Work Orders	7/17/2007 7/25/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 509
3371	Hvac 612 not cooling, unit seems to be running normally. welcome center is 83 degrees Closed Work Orders	7/20/2007 7/25/2007	Rob Bauer	Held, David	Gateway Elementary School Administration Area welcome center
3392	HVAC 805 has gone down, reset unit but it still does not come on. Classroom @ 85 degrees and rising at last check Closed Work Orders	7/23/2007 7/25/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 805
3395	toilet in south staff bathroom does not flush properly, you must hold the handle down until all items have been flushed. as soon as you let go of the handle, flush operation ceases. adjusted top screw with no change in flushing proceedure Closed Work Orders  installed new diaphram, and flush handle kit.	7/23/2007 7/24/2007	Rob Bauer	Johnson, Scott	Gateway Elementary School Kitchen staff bath
3408	Dave, The teacher in classroom 602 says that when the air comes on its intense heat for about ten to fifteen minutes before it cools down, she is ready to take her kids to another classroom. I checked the degree spread and its a 6 degree spread. (HVAC 602) Closed Work Orders	7/24/2007 7/25/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 602
3475	Hvac 865 not cooling P.E. office. unit is on, fan is not Closed Work Orders	7/27/2007 8/1/2007	Rob Bauer	Held, David	Gateway Elementary School Gym P.E. office/ bathrooms
3484	HVAC 406, the fire damper has closed Closed Work Orders	7/30/2007 8/1/2007	Rob Bauer	Held, David	Gateway Elementary School Hallway/Corridor
3549	grease holding tanks full. Closed Work Orders  a american septec pumped out tank.	8/3/2007 8/7/2007	Scott Johnson	Johnson, Scott	Gateway Elementary School
3553	HVAC 865 not cooling P.E. office and Bathrooms. P.E. have to keep the MPR door open to cool office. Same problem as before Closed Work Orders	8/3/2007 8/7/2007	Rob Bauer	Held, David	Gateway Elementary School Administration Area P.E. office
3563	HVAC 500 has gone down. cant seem to reset it. unit is completely off Closed Work Orders	8/6/2007 8/7/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 500

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
3564	HVAC 406 blowin hot Closed Work Orders	8/6/2007 8/7/2007	Rob Bauer	Held, David	Gateway Elementary School Hallway/Corridor
3613	HVAC 856 spewing hot air into classroom, about 84 degrees Closed Work Orders	8/10/2007 8/16/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 856
3646	HVAC 604 has gone down, I havent had a chance to check it out yet, could you have a look? Closed Work Orders	8/15/2007 8/16/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 604
3647	HVAC 856 has finally come back online with the computer, still shows discharge air at 84 degrees, room very warm. Closed Work Orders	8/15/2007 8/16/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 856
3649	HVAC 505 will not cool, only blows extremely hot air. it got to 140 degrees yesterday before I shut it down. this morning i turned the fan back on and it immediatly went up from 83 degrees. I have the fan shut down right now (override) on the computer Closed Work Orders	8/15/2007 8/16/2007	Rob Bauer	Held, David	Gateway Elementary School Administration Area 505
3758	Dave, one of the reach ins is running warm, i cranked it all the way up and it only got down to 46 degrees Closed Work Orders	8/24/2007 8/27/2007	Rob Bauer	Held, David	Gateway Elementary School Kitchen
3771	Dave, HVAC 201 didnt seem to cool the Kindergarten room down so well yesterday, when I checked it out , the bottom half of the coil was iced over. This morning when i checked it out it didnt seem to be blowing into the room. The temp reached 82 yesterday by 1:00, hopefully you can check it out before they start heating up today Closed Work Orders	8/28/2007 8/28/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 201
3865	HVAC 604 has quit working, reset unit but would not come on or online Closed Work Orders	9/13/2007 9/18/2007	Rob Bauer	Held, David	Gateway Elementary School Classroom 604
3971	Walk-in Refrigerator is at 50 degrees. Alys did check breaker and it is okay. Please check ASAP before all food goes to waste. I appreciate your work. Thank you, Angie. Closed Work Orders	9/25/2007 9/28/2007	Angie Marquez	Held, David	Gateway Elementary School Cafeteria CAFETERIA

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
4192	Dave, the very south reach in is not maintaining the correct temp, could you have a look...thanks Closed Work Orders	11/13/2007 11/14/2007	Rob Bauer	Held, David	Gateway Elementary School Kitchen
4214	Tom, not sure if this is you, but the ice machine @ Gateways kitchen is acting strange, keeps shutting down and tripping the breaker. Alys is hoping you can check this out soon, no ice in kitchen...thanks Closed Work Orders	11/15/2007 11/28/2007	Rob Bauer	Held, David	Gateway Elementary School Kitchen
4314	hvac 505 will not heat, came on this morning and started blowing 37 degrees and would not stop. Tried to override and turn heat pump on but still only discharged 37 degrees. turned off system at computer and unit continued to blow cold, I will reset unit and see what happens. Could you have a look as well? Thanks Dave. Closed Work Orders	12/4/2007 12/20/2007	Rob Bauer	Held, David	Gateway Elementary School Administration Area 505
4320	Ice machine is not working again. I have spoken to Dave and he will check it out again. Thank you, Angie. Closed Work Orders	12/4/2007 12/11/2007	Angie Marquez	Held, David	Gateway Elementary School Cafeteria KITCHEN
4331	HVAC 801 has dropped offline, tried to reset unit but will not come on. Closed Work Orders	12/5/2007 12/20/2007	Rob Bauer	Held, David	Gateway Elementary School  801
4529	HVAC 506 not heating room, reset unit with no results Closed Work Orders	1/16/2008 1/18/2008	Rob Bauer	Held, David	Gateway Elementary School Classroom 506
4530	Remember the problem we had with HVAC 801, Scott told me that we will put the controller on capital, in the meantime, could you install a new stat to be controlled from the room, there is absolutely no heat in that room right now. Thanks Dave. Closed Work Orders	1/16/2008 1/18/2008	Rob Bauer	Held, David	Gateway Elementary School Classroom 801
4620	Dave, HVAC 506 is acting funny, The heat will come on and discharge temp gets up to the upper 80's then goes down to the 50's. I have 6 degrees of seperation and it just goes up and down all day Closed Work Orders	1/31/2008 2/11/2008	Rob Bauer	Held, David	Gateway Elementary School Classroom 506
4967	HVAC 404 heating up classroom and wont cool down, discharge air will not go below 84 degrees Closed Work Orders	4/7/2008 4/28/2008	Rob Bauer	Held, David	Gateway Elementary School Classroom 404

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
4982	Hey Dave, I know you probably just left here for unit 404, but HVAC 201 just went down, unit will not come on at all...thanks again Closed Work Orders	4/8/2008 4/11/2008	Rob Bauer	Held, David	Gateway Elementary School Classroom 201
5123	Dave, the reach in fridges are warming up again Closed Work Orders	4/30/2008 5/5/2008	Rob Bauer	Held, David	Gateway Elementary School Kitchen
5243	Check A/C #600 Closed Work Orders	5/16/2008 5/19/2008	David Held	Held, David	Gateway Elementary School  600
5251	HVAC 505 blowin 150 degrees and wont cool, shut unit down Closed Work Orders	5/20/2008 5/23/2008	Rob Bauer	Held, David	Gateway Elementary School  505
5563	Scott, One of the drinking fountains on the Plant foreman office is missing the spacer and the screw that holds the basin to the fountain. Could you please come look at it.  Closed Work Orders replaced missing parts.	7/15/2008 7/17/2008	Rich Keppler	Johnson, Scott	Gateway Elementary School Sidewalk
5731	AC down Closed Work Orders	7/21/2008 7/22/2008	Sonya Chavez	Held, David	Gateway Elementary School Classroom 600
5732	AC is not working well. Closed Work Orders	7/21/2008 7/22/2008	Sonya Chavez	Held, David	Gateway Elementary School Other Welcome Center
5965	Ac is not blowing cold in the welcome center. Closed Work Orders	8/4/2008 8/5/2008		Held, David	Gateway Elementary School Administration Area Welcome Center
6039	AC unit for room 801 has a possible compressor failure. Unit was shut down. Also the exhaust fan motor has failed. Closed Work Orders	8/7/2008 8/11/2008		Held, David	Gateway Elementary School Maintenance & Operations 801
6103	My pull down screen broke and the screw came out that holds on the handle. Closed Work Orders	8/11/2008 8/13/2008	courtney nurnberg	Hatton, Duane	Gateway Elementary School Classroom 404
6112	reach in cooler by office are not working, temp at 60 degrees on one and 58 on the other. Closed Work Orders	8/12/2008 8/15/2008	alys casperson	Held, David	Gateway Elementary School Kitchen 48851
6148	The discharge fan on unit 600 may have a bearing failure soon. It is making a lot of noise Closed Work Orders	8/14/2008 8/18/2008		Held, David	Gateway Elementary School Wing 600 unit

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
6149	unit 813 the library hallway unit, discharge (condensation fan) has failed. I have been monoterling it and it has never kicked on. Closed Work Orders	8/14/2008 8/15/2008		Held, David	Gateway Elementary School Library Hallway unit
6151	A/C Unit 500 not working Closed Work Orders	8/14/2008 8/15/2008		Held, David	Gateway Elementary School Classroom 500
6159	hot box on far side not up to temp. also cold box across from regester still reading 53 degrees Closed Work Orders	8/14/2008 8/22/2008	alys casperson	Held, David	Gateway Elementary School Cafeteria 851
6493	ice machine still not working, not making ice, please check out Closed Work Orders	9/3/2008 9/17/2008	alys casperson	Held, David	Gateway Elementary School Kitchen 851
6494	freezer door will not close, ice build up prevents closeing untill we knock ice off the door. Closed Work Orders	9/3/2008 9/17/2008	alys casperson	Held, David	Gateway Elementary School Kitchen 851
6533	Several toilets are not flushing unless held in the up position. girls by the Library girls K, 3 dont flush Ladies staff by 300 P2 girls Closed Work Orders  repaired two drinking fountains and three toilets. rest of job on hold for parts.walked campus repaired all toilets and sink drains found in need of repair.	9/5/2008 9/15/2008		Johnson, Scott	Gateway Elementary School Gateway
6612	Freezer gave out on Friday. Could it be checked ASAP!!! please. Thank you, Angie.  Closed Work Orders	9/15/2008 9/18/2008	Angie Marquez	Held, David	Gateway Elementary School Cafeteria Freezer Area
6679	ice maachine not making ice again, made ice 1 day, went down Closed Work Orders	9/18/2008 9/22/2008	alys casperson	Held, David	Gateway Elementary School Kitchen 85-
6739	the metal pieces that hold the screen down have fallen apart Closed Work Orders Replaced bolts and adjusted	9/22/2008 9/23/2008	Jada pomeroy	Hatton, Duane	Gateway Elementary School Classroom 305
6779	Kids have pulled the over flow off again..only this time they held it down and flooded the restroom. Now it locked Closed Work Orders epoxied back together.	9/25/2008 9/26/2008		Johnson, Scott	Gateway Elementary School Restroom Next to 800
6895	walk in refreigator going out blowing warm air tempature is 50 degrees at 9am Closed Work Orders	10/14/2008 10/15/2008	alys casperson	Held, David	Gateway Elementary School Kitchen 851

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
6962	I am wondering if we could possibly get a chain like the one we have on the bathroom door installed on the changing room door. I also wanted to let you know that the plaster on the wall in the changing room did not hold up. It started cracking today. Closed Work Orders	10/17/2008 11/6/2008	mary jordan	Hatton, Duane	Gateway Elementary School Classroom 855
7106	A/C unit for room 605 has shut down. Tried a reset and still it didn't power up. EMS shows no communication with the unit. Closed Work Orders	10/31/2008 11/4/2008		Held, David	Gateway Elementary School  605
7212	Check A/Cs & replace pulleys on blower motors. Closed Work Orders	11/7/2008 2/24/2009		Held, David	Gateway Elementary School
7397	We need 8 folding chairs delivered to my room by 10 am tomorrow 11/26. we also need the hole in the wall in the changing room or office of our room repaired again as previous repairs are not holding. We also need a roll of paper towels. Closed Work Orders	11/25/2008 11/26/2008	mary jordan	Hatton, Duane	Gateway Elementary School Classroom 855
7493	The heat is not working in room 202, Mrs. Quintanilla's classroom. Cold air is blowing out of the vent again. Closed Work Orders	12/5/2008 12/9/2008	Amy Burgess	Held, David	Gateway Elementary School Maintenance & Operations 202
7514	EMS is not responding, need Johnson Controls to reset. Will have Dave verify Heating is blowing air but not heating. Closed Work Orders	12/8/2008 12/10/2008		Held, David	Gateway Elementary School
7620	The bookshelf on the back wall has a self that broke. It needs to be nailed in so it will hold the books. I put the shelf right by the bookshelf. Closed Work Orders	12/17/2008 1/6/2009	courtney nurnberg	Hatton, Duane	Principles office Gateway Elementary School Classroom 404
7626	Welcome Center A/C unit froze up and power off. Please take a look. Closed Work Orders	12/18/2008 1/7/2009		Held, David	Gateway Elementary School
7792	Unit is blowing A/C and no heat. EMS is sending the commands but the unit is not accepting them. The unit is currently shut down. Closed Work Orders	1/6/2009 1/7/2009		Held, David	Gateway Elementary School  505
8196	Monthly - PM Schedule created on 12/10/2008 - Refer to PM schedule details. Closed Work Orders	2/18/2009 2/24/2009	Roy Sucanick	Held, David	Gateway Elementary School



WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
8296	Offie unit is not cooling. EMS is communicating. Closed Work Orders	3/2/2009 3/3/2009		Held, David	Gateway Elementary School Administration Area Office
8332	A/C is not cooling. There is power and the unit is working. Had a clean filter but replaced it anyway and noticed ice build up. Closed Work Orders	3/5/2009 3/6/2009		Held, David	Gateway Elementary School Maintenance & Operations BMW Shop
8414	One of Gateway's Milk Coolers is reading 60 degrees. Please check ASAP. Thank you, Angie. Closed Work Orders	3/23/2009 3/25/2009	Angie Marquez	Held, David	Gateway Elementary School Cafeteria Cafeteria
8494	Condensers on reach in referigators need to be vacumed check freon in 2 units both next to work tables Closed Work Orders	4/2/2009 4/7/2009	alys casperson	Held, David	Gateway Elementary School Kitchen 851
8551	I have used the thermostat in my room, but the air does not circulate, and it's hot!! Closed Work Orders EMS thinks its on an working, shut down for 30 sec to reset without success. Forward to Dave.	4/14/2009 4/17/2009	Donna Erwin	Held, David	Gateway Elementary School Classroom 607
8744	AC unit does not respond to the EMS. Performed a reset and had no success to start the unit. Closed Work Orders	5/11/2009 5/14/2009		Held, David	Gateway Elementary School Office unit
9039	stat is not reading corectly Closed Work Orders	7/1/2009 7/14/2009		Held, David	Gateway Elementary School Administration Area front office
9190	Dave, The A/C unit for room #601 fan is not working. Could you please come look at? Rich Closed Work Orders	7/29/2009 7/29/2009	Rich Keppler	Held, David	Gateway Elementary School Classroom
9397	A/C in the P.E. office is not working properly; it is much warmer than other rooms. Closed Work Orders reset system, system checked ok	8/7/2009 8/10/2009	Tom Gabriele	Held, David	Gateway Elementary School Gym 860
9438	cold box behind line not holding proper tempeture, dish washer not getting any water light out in dishwasher area tiles missing on several areas in kitchen  Closed Work Orders Repaired, Dave	8/10/2009 8/31/2009	alys casperson	Keppler, Rich	Gateway Elementary School 851

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
9669	A/C will not cool below 82, I have reset unit twice. Closed Work Orders	8/24/2009 8/24/2009		Held, David	Gateway Elementary School Classroom 704
9713	reach in refrigirator behind serving line, not holding proper temp. of 41 degrees coils were vacumed 2 weeks ago but still not working properly. can we check all of them for possible freon loss?  Closed Work Orders	8/26/2009 8/31/2009	alys casperson	Held, David	Gateway Elementary School Cafeteria 851
9728	A/C not comming on. Reset system Closed Work Orders	8/27/2009 8/28/2009		Held, David	Gateway Elementary School Classroom 509
9752	I think the air conditioning in my room is broken or I am not able to do anything with it. It has been getting progressively hotter in my room over the last week. The air does not even sound like it is on any more. There is no air flow and it is not cooling off at all. Closed Work Orders  system has been reset twice and fails to cool below 81.	8/31/2009 9/1/2009	Annie Liss	Held, David	Gateway Elementary School Classroom 801
9834	room is hot! no air Closed Work Orders	9/8/2009 9/10/2009	John garone	Held, David	Gateway Elementary School Classroom p2/room 509
9873	drinking fountain facing ball field is plugged also missing center nut to hold catch basin in place Closed Work Orders  cleared line and put center nut in place	9/10/2009 9/17/2009	Scott Johnson	McVey, Jim	Gateway Elementary School Playground p3
9916	unit #851 and unit 849 the fan for the condensor is spinning slow it is a large unit with two fans i believe it is a ten ton unit Closed Work Orders	9/15/2009 9/18/2009	David Held	Held, David	Gateway Elementary School Multi-purpose Room 851@849
9924	unit 612 when i changed filters half of the coils were frozen solid i shut down unit Closed Work Orders	9/15/2009 9/17/2009	Jim McVey	Held, David	Gateway Elementary School Administration Area 612
10005	Air Conditioning will not come on. The room is very warm. Closed Work Orders	9/17/2009 9/18/2009	Lisa Barry	Held, David	Gateway Elementary School Classroom 806
10013	ac unit not cooling the room shut down unit Closed Work Orders	9/17/2009 9/18/2009		Held, David	Gateway Elementary School Classroom 806

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
10040	The air conditioning in my classroom is still not working. It is very hot in the classroom. Closed Work Orders	9/21/2009 9/24/2009	Lisa Barry	Held, David	Gateway Elementary School Classroom 806
10091	The air conditioning is out in my classroom. Room 806. Closed Work Orders forwarded to dave the ac guy he fixed it	9/24/2009 9/25/2009	Lisa Barry	Held, David	Gateway Elementary School Classroom 806
10162	ac unit does not work please fix thanks jim Closed Work Orders	9/30/2009 10/7/2009		Held, David	Gateway Elementary School Classroom 859
10163	the computer says the south hall and the library south hall are putting out air temps at 86 degrees and the units are running Closed Work Orders	9/30/2009 10/1/2009		Held, David	Gateway Elementary School Hallway/Corridor
10164	computer says the air in the faculty dining room is putting out air at 90 degrees and the unit is running Closed Work Orders	9/30/2009 10/1/2009		Held, David	Gateway Elementary School Cafeteria faculty dining room
10180	ac is out please take a look at thanks jim Closed Work Orders	10/1/2009 10/7/2009		Held, David	Gateway Elementary School Classroom 500
10191	unit 847 i believe that we looked at the other day you said wasn't getting a signal scott looked at today and said the stat is bad go ahead and put a regular programable stat on thanks jim Closed Work Orders	10/2/2009 10/7/2009		Held, David	Gateway Elementary School Kitchen kitchen
10197	Freezer not working, temp not going below 28 degrees Closed Work Orders	10/5/2009 10/7/2009	alys casperson	Held, David	Gateway Elementary School Kitchen 851
10244	ac is stuck on in cooling mode and won't shut down they are having a meeting in this room until 12 noon thanks jim Closed Work Orders	10/8/2009 10/12/2009		Held, David	Gateway Elementary School Cafeteria 859
10308	Air conditioning will not go on Closed Work Orders	10/19/2009 10/22/2009	Rosemary Sciara	Held, David	Gateway Elementary School Classroom 702
10387	dave can you check out units 608 and 813 they are hallway units but don't seem to be working properly also unit 406 appears to be shut down no rush when you have time thanks jim Closed Work Orders	10/27/2009 10/30/2009		Held, David	Gateway Elementary School Hallway/Corridor roof

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
10487	blower on door doesnot work/magnets on doors do not hold Closed Work Orders done.	11/5/2009 3/4/2010	John garone	Huff, Tom	Gateway Elementary School Kitchen kitchen/cafeteria
10603	in trash dumpster area there is a walk behind vaccum for the grounds out side needs new tires one doesn't hold air also won't start please look at and repair when possible thanks Complete Done	11/16/2009 11/25/2009	Jim McVey	Gere, Val	Gateway Elementary School Grounds
10701	Freezer went into defront cycle about 10:30ish this morning. Breakers were checked and okay. I called Dave so he can check it out ASAP. Thanks, Angie. Closed Work Orders	12/1/2009 12/2/2009	Angie Marquez	Held, David	Gateway Elementary School Kitchen FREEZER
10779	It's TOOOOO COLD!!! Closed Work Orders	12/9/2009 12/10/2009	Christina Boston	Held, David	Gateway Elementary School Classroom 801 - LISS
10787	the heat is not working in the classroom i think maybe the tstat is not working can you check it out thanks jim Closed Work Orders	12/9/2009 12/14/2009		Held, David	Gateway Elementary School Classroom 801
10790	dave i have several units on the roof of the cafeteria that the external coils are freezing i shut units down let me know how i can help thanks Closed Work Orders	12/10/2009 12/14/2009		Held, David	Gateway Elementary School Classroom cafeteria building
10799	heat not running please fix thanks dave Closed Work Orders	12/10/2009 12/14/2009		Held, David	Gateway Elementary School Administration Area unit 613 nurses office
10800	heat not working Closed Work Orders	12/11/2009 12/16/2009		Held, David	Gateway Elementary School Classroom 604
10812	teacher says cold in class room tstat for room is not registering room temp when i try to turn on heating or cooling it doesn't do anythig please check it out for me dave thanks Closed Work Orders	12/14/2009 12/16/2009		Held, David	Gateway Elementary School Classroom 506
10944	The A/C in my office is being on instead of the heather system. As a result of that this office is very cold. ( Room 860, P.E. office) Can you turn of the A/C and activate the heather please? Thank you dave the heat is kicking on just not working properly can you check this out thanks Closed Work Orders	1/13/2010 1/19/2010	Alberto Ramos	Held, David	Gateway Elementary School Other 860

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
10982	the ac unit on room 503 is not working i think either the fuse is blown or maybe a bad ground could you check it out please dave thanks Closed Work Orders	1/15/2010 1/19/2010		Held, David	Gateway Elementary School Classroom room 503
11439	one of the crash bars in room 807 is loose and gets hung up it is the one on the west side thanks Closed Work Orders	3/25/2010 4/20/2010		Held, David	Gateway Elementary School Classroom 807
11479	Can you check to see how much helium is left in the tank please? Closed Work Orders	4/1/2010 4/20/2010	Christina Boston	Held, David	Gateway Elementary School Media Center library
11482	Install Garageband software on computers Asset: 603381 603380 604089 604098 604086 604088 604100 604101 604104 604092 603382 604091 604097 Closed Work Orders	4/1/2010 4/20/2010	Katherine paetz	Held, David	Gateway Elementary School Classroom 856
11530	Gum Removal on Carpet by door Closed Work Orders	4/8/2010 4/20/2010	Rosemary Sciara	Held, David	Gateway Elementary School Classroom 702
11762	ice machine not making ice. also milk box not holding tempeture ( milk box next to managers office) Closed Work Orders	5/12/2010 5/14/2010	alys casperson	Held, David	Gateway Elementary School Kitchen 851
11802	I do not have a/c in my classroom - yikes! the blower is running and the computer shows it is in ac mode but the condensor fan is not turning Closed Work Orders	5/18/2010 5/21/2010	Deborah Smith	Held, David	Gateway Elementary School Classroom P2-509
11888	please REMOVE the light bulbs from the center light fixture that is right in front of the smart board. Also, the filing cabinet behind teacher desk needs repair. The bars that hold up the files are falling down. Closed Work Orders	5/26/2010	Jada pomeroy	McVey, Jim	Gateway Elementary School Classroom 305

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
11937	The shelf in the green cabinet needs to be fixed. In the lower right side of the big green cabinet the peg that holds up the shelf broke and now the shelf is falling down.  Thank you!!  Closed Work Orders	5/28/2010	courtney nurnberg	McVey, Jim	Gateway Elementary School Classroom 404
12055	The top shelf of my filing cabinet (behind teacher desk) is still broken. The bars that hold up the files in the cabinet have fallen down and need to be reattached. Closed Work Orders	6/15/2010	Jada pomeroy	McVey, Jim	Gateway Elementary School Classroom 305
12667	hot box reach in not holding temperature, next to managers office Closed Work Orders completed.	9/2/2010 9/10/2010	alys casperson	Huff, Tom	Gateway Elementary School Kitchen 851
12836	I need one new table that seats 4 kids with the cubbies built in to hold their books please. Closed Work Orders	9/22/2010	Jada pomeroy	McVey, Jim	Gateway Elementary School Classroom 305
13032	parking lot entry please make three post that will mount to the concrete and hold a rope inside Closed Work Orders fabbed posts	10/22/2010 1/25/2011		Belzner, Steve	Gateway Elementary School
13434	Bookshelves are falling, they need hooks to hold the shelves up. (bookshelf in the back of the room and also next to the sink) Closed Work Orders	12/9/2010 1/5/2011	Erin Tucker	McVey, Jim	Gateway Elementary School Classroom 607
14474	reach in referigator behind serving line not holding temp coils have been cleaned off still not working Complete put freon in unit	5/5/2011 5/27/2011	alys casperson	Rascon, Javier	Gateway Elementary School Kitchen 851
16724	These items require attention: There are 2 white boxes that are sitting above the sink area that need lowering to the ground please.  The cleaning crew knocked down the mini blinds when they cleaned the room and they did not put them back into place. Please check both sets of blinds for function.  There is one shelf that is lose and requires a small bracket to hold it up. This is the large shelf that is part of the south wall. Closed Work Orders	7/31/2012 8/2/2012	maria perez	McVey, Jim	Gateway Elementary School Classroom 301

# Search Results

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
12190	the freezer at gateway the lines on the unit keep freezing up please look at when you get a chance Closed Work Orders fixed unit was low on freon	7/20/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Cafeteria
12191	two of the pass through fridges are not getting cold enough reading 50-52 degrees please check out Closed Work Orders fixed both units had restrictions in cappillary tubes.	7/20/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Cafeteria
12197	please check out walk in freezer when you get a chance i think it is icing up Closed Work Orders fixed	7/22/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Cafeteria
12198	please check out ac in front office unit 111 i don't think it is working properly not cooling like it should Closed Work Orders fixed low on freon	7/22/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Administration Area
12341	the ac is not working stat is blank and there are two blown fuses at disconnect on the roof Closed Work Orders replaced fuse	8/5/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Classroom 506
12342	please check ac not running Closed Work Orders charged up with freon	8/5/2010 8/18/2010		Rascon, Javier	Gateway Elementary School Cafeteria 849
12343	please check out ac i don't think it is cooling like it should Closed Work Orders fixed	8/5/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Hallway/Corridor unit 815
12344	ac not working Closed Work Orders	8/5/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Hallway/Corridor 608
12420	can you please check out the air on the pe office doesn't seemt to be working thanks Closed Work Orders	8/10/2010 8/16/2010		Rascon, Javier	Gateway Elementary School Administration Area

WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
12565	Drain under ice machine needs new grate the one noe is all rusty. Also leg has comme off left front as you face the machine  Ceiling above stove has begun leaking around 12:30 each day this starts, hot box reach in near managers office has began to make a weird noise during lunch serving time, could it be checked out Closed Work Orders  cleaned up old grill and repainted	8/19/2010 8/31/2010	alys casperson	Rascon, Javier	Gateway Elementary School Kitchen 851
12593	The air conditioning is not working. Please fix it.  Thanks! Closed Work Orders  fixed was low on freon charged up with 2lbs.	8/24/2010 9/2/2010	Charisa Lackrone	Rascon, Javier	Gateway Elementary School Classroom 304
12598	check one of the units on the cafeteria i don't believe is cooling thanks unit #861 mpr s. west Closed Work Orders  unit running good	8/24/2010 8/31/2010		Rascon, Javier	Gateway Elementary School Cafeteria
12599	check ac unit was not bringing down room temp thanks Closed Work Orders  was low on freon charged up with three pounds of freon	8/24/2010 8/31/2010		Rascon, Javier	Gateway Elementary School Classroom 303
12683	It has been very hot in here. It is over 80 degrees. THank you. Complete	9/7/2010 9/15/2010	Karen maxwell	Rascon, Javier	Gateway Elementary School Classroom 403
12686	room 403 the air is not working can you please check it out thanks Complete  was low o freon put 3lbs in.	9/7/2010 9/15/2010		Rascon, Javier	Gateway Elementary School Classroom 403
13169	there are two reach in coolers in the cafeteria kitchen not working please check this out thanks Complete  added a few pounds of freon	11/12/2010 11/19/2010		Rascon, Javier	Gateway Elementary School Kitchen
13654	room 502 at gateway the night crew said the heat got stuck on and the room was really hot last night please check it out thanks Complete  adjust and and lock settings so whomever played with the settings can not mess up t- stat again	1/12/2011 1/14/2011		Rascon, Javier	Gateway Elementary School Classroom 502
13694	the ice machine alys says is not working keeps kicking breaker please check it out thanks Complete  unit is running fine	1/19/2011 2/15/2011		Rascon, Javier	Gateway Elementary School Cafeteria



WOID	Description Status Action Taken	Request Date Completion Date	Requester	Assigned To	Location Area Type Area Number
13696	milk box in kitchen water from condensation causing box to rust. please check out to see if we can stop water build up over nite . Complete it is normal condinsation	1/19/2011 2/15/2011	alys casperson	Rascon, Javier	Gateway Elementary School Kitchen 851
13717	400 hall way unit is shut down i have a wet spot in the ceiling when i went up to check it out all the pipes around the compressor were frozen and part of the compressor i shut it down thanks Complete evacuated system and recharged.	1/21/2011 2/15/2011		Rascon, Javier	Gateway Elementary School Hallway/Corridor
13795	no heat Complete fixed	2/3/2011 2/18/2011		Rascon, Javier	Gateway Elementary School Classroom 300
13796	no heat Complete fixed	2/3/2011 2/18/2011		Rascon, Javier	Gateway Elementary School Cafeteria 601
13797	heat stuck on Complete fixed	2/3/2011 2/18/2011		Rascon, Javier	Gateway Elementary School Classroom 502
13798	welcome center no heat Complete fixed	2/3/2011 2/18/2011		Rascon, Javier	Gateway Elementary School Administration Area
13799	no heat Complete fixed	2/3/2011 2/18/2011		Rascon, Javier	Gateway Elementary School Classroom 806
13800	no heat Complete fixed	2/3/2011 2/18/2011		Rascon, Javier	Gateway Elementary School Classroom 810-812
13823	unit is blowing cold air please check it out thanks Complete adjusted amount of outdoor air that mix's in	2/7/2011 2/15/2011		Rascon, Javier	Gateway Elementary School Classroom 202
13920	ac not working please check it out thanks Complete put new reversing valve in unit	2/18/2011 3/2/2011		Rascon, Javier	Gateway Elementary School Classroom 506
14229	six hundred wing staff bathrooms exhaust fan motors are bad please replace Complete replaced exhaust fan motor	4/6/2011 4/15/2011		Rascon, Javier	Gateway Elementary School Bathroom
14230	staff bathroom in the 200 wing replace exhaust fan motor thanks Complete replaced exhaust fan	4/6/2011 4/15/2011		Rascon, Javier	Gateway Elementary School Bathroom
14231	replace out door fan motor library unit thanks Complete replaced outdoor motor	4/6/2011 4/15/2011		Rascon, Javier	Gateway Elementary School Media Center